

CB TEST CERTIFICATE CERTIFICAT D'ESSAI OCProduct
Produit

LED controlgear

Name and address of the applicant
Nom et adresse du demandeurMean Well Enterprises Co., Ltd.
No.28, Wuquan 3rd Rd., Wugu Dist.
New Taipei City 248
TaiwanName and address of the manufacturer
Nom et adresse du fabricantMean Well Enterprises Co., Ltd.
No.28, Wuquan 3rd Rd., Wugu Dist., New Taipei City
New Taipei City 248
TaiwanName and address of the factory
Nom et adresse de l'usineNote: When more than one factory, please report on page 2
Note: Lorsque il y plus d'une usine, veuillez utiliser la deuxième page Additional information on page 2Ratings and principal characteristics
Valeurs nominales et caractéristiques principales0.27A 200-240VAC 50/60Hz for LCM-40.;
0.37A 200-240VAC 50/60Hz for LCM-60.
Cl. I. tc: 90°C, pf: 0.95, independent SELV, constant current.
DC-output and ta:
LCM-60.: 0.5A +90V, ta: 50°C; 0.6A +90V, ta: 50°C; 0.7A +86V, ta: 50°C;
0.9A +67V, ta: 50°C; 1.05A +57V, ta: 40°C; 1.4A +42V, ta: 40°C
LCM-40.: 0.35A +100V, ta: 50°C; 0.5A +80V, ta: 50°C; 0.6A +67V, ta:
50°C; 0.7A +57V, ta: 50°C; 0.9A +45V, ta: 50°C; 1.05A +40V, ta: 40°CTrademark (if any)
Marque de fabrique (si elle existe)Type of Manufacturer's Testing Laboratories used
Type de programme du laboratoire d'essais constructeurModel / Type Ref.
Ref. De type

LCM-..

Additional information (if necessary may also be reported on page 2)
Les informations complémentaires (si nécessaire, peuvent être indiqués sur la deuxième page)

The first dot "." in the model name can be 40 or 60, denote output power. Last dot "." can be DA (with dimming) or blank (without dimming), denote with or without dimming function.

 Additional information on page 2A sample of the product was tested and found to be in conformity with
Un échantillon de ce produit a été essayé et a été considéré conforme à laIEC 61347-1(ed.2);am1
IEC 61347-2-13(ed.1)As shown in the Test Report Ref. No. which forms part of this Certificate
Comme indiqué dans le Rapport de tests numéro de référence qui constitue partie de ce Certificat

234753-A

This certificate replaces certificate NO74844 issued 29-04-2013, due to correction of the standard.

This CB Test Certificate is issued by the National Certification Body
Ce Certificat de test OC est établi par l'organisme National de CertificationGaustadalléen 30
NO-0373 Oslo, Norway*Hanne Yndestad*

Date: 16-05-2013

Signature: Hanne Yndestad
Certification Department



Ref. Certif. No.

NO74844/A1

Mean Well Enterprises Co., Ltd.
No.28, Wuquan 3rd Rd., Wugu Dist.
New Taipei City 248
Taiwan

Mean Well (Guangzhou) Electronics Co., Ltd.
2nd Floor No. A Building, Yuean Ind. Park
Dongpu Town, TianHe Dist., Guangzhou, P.R.
China

Additional information(if necessary)
Information complémentaire (si nécessaire)



Gaustadalléen 30
NO-0373 Oslo, Norway

Date: 16-05-2013

Hanne Yndestad

Signature: Hanne Yndestad
Certification Department